



TRENCH	
PIPE DIA.	WIDTH
12"	36"
15"	36"
18"	40"
24"	48"
30"	66"
36"	78"
48"	90"

NOTES:

1. BEDDING SHALL BE No.6 (3/4") CRUSHED STONE (DOT FORM 816 M.01.01)
2. UNSUITABLE MATERIAL BELOW NORMAL GRADE SHALL BE REPLACED WITH No.6(3/4") CRUSHED STONE (CONNDOTFORM 816, ART. M.01.01) AS DIRECTED BY THE CITY ENGINEER.
3. ALL WORK MUST BE CONDUCTED IN STRICT ACCORDANCE WITH THE LATEST REGULATIONS OF OCCUPATIONAL SAFETY AND HEALTH ADMINISTRATION (OSHA)FOR EXCAVATIONS.

TYPICAL STORM DRAINAGE TRENCH HDPE NON-PAVED AREAS

NOT TO SCALE

SCALE N.T.S.	CITY OF TORRINGTON Engineering Department
APPROVED	
RV. DATE	TYPICAL STORM DRAINAGE TRENCH HDPE NON-PAVED AREAS
JAN. 2002	
APR. 2009	
AUG. 2011	