



NOTES:

1. REINFORCED CONCRETE MANHOLE SECTIONS CONFORMING TO ASTM C-478.
2. RUBBER LIFT HOLE PLUGS TO BE INSERTED FROM THE OUTSIDE AND HOLE FILLED WITH NON-SHRINK INSIDE AND OUTSIDE.
3. TYPE "A" MANHOLE SHALL BE 48" IN DIAMETER.
4. TYPE "B" MANHOLE SHALL BE SAME AS "A" EXCEPT IT SHALL BE 60" IN DIAMETER.
5. TYPE "C" MANHOLE SHALL BE SAME AS "A" EXCEPT IT SHALL BE 72" IN DIAMETER.
6. TYPE "D" MANHOLE SHALL BE SAME AS "A" EXCEPT IT SHALL BE 84" IN DIAMETER.
7. TYPE "E" MANHOLE SHALL BE SAME AS "A" EXCEPT IT SHALL BE 96" IN DIAMETER.
8. ALL MANHOLE BASES SHALL BE REDUCED TO 48" DIAMETER STD RISER SECTIONS UNLESS INDICATED OTHERWISE ON THE CONTRACT DRAWINGS
9. THERE WILL BE NO STEPS IN ANY MANHOLE.
10. VACUUM TEST REQUIRED
11. RISER SHALL CONTAIN NO INTERIOR STEPS OR HOLES FOR STEPS.

PRE-CAST MANHOLE

NO SCALE

SCALE N.T.S.	CITY OF TORRINGTON Engineering Department
APPROVED	
RV. DATE	PRE-CAST SANITARY MANHOLE
JAN. 2002	
FEB. 2007	
AUG. 2011	